

EC Conformity Declaration

Document No.:	3099
Month . Year:	12/08

Manufacturer: WAGO Kontakttechnik GmbH & Co. KG

Address: Hansastraße 27 32423 Minden

Germany

Product designation: Compact connector for all conductor types

Series 222

The designated product conforms to the provisions of the following European directives:

2006/95/EEC (Low Voltage Directive)

Electrical Equipment designed for use within

certain voltage limits

The conformity of the designated products with the requirements of this directive is proven by the complete accordance with the following standards.

EN 60998-1; 2004 Connecting devices for low-voltage circuits for household and

similar purposes.

Part 1: General requirements

EN 60998-2-2; 2004 Connecting devices for low-voltage circuits for household and

similar purposes.

Part 2-2: Particular requirements for connecting devices as

separate entities with screwless-type clamping units.

Issuer: WAGO Kontakttechnik GmbH & Co. KG

Hansastraße 27 32423 Minden Germany

Place, date: Minden, December 16, 2008

Legally binding signature:

Technical Director

The Annexes are integral part of this declaration.

This declaration certifies compliance with the indicated directives but implies no warranty of properties.

The safety instructions of the accompanying product documentation shall be observed.

ENEC CERTIFICATE

Connecting devices as separate entities with screwless—type clamping units (EN 60998–2–2)

Product:

Terminal blocks

Manufacturer:

Wago Kontakttechnik GmbH,

Production site:

Hansastrasse 27, Postfach 2880, D-32423 Minden, Germany

See Appendix

Certificate holder:

Wago Kontakttechnik GmbH,

Hansastrasse 27, Postfach 2880, D-32423 Minden, Germany

Wago Kontakttechnik GmbH,

Hansastrasse 27, Postfach 2880, D-32423 Minden, Germany

WACO

Trademark:

Series 222 (See Appendix)

Rated current or power:

Certified by request of:

-

Rated voltage:

Model/Type ref .:

450 Vac

Rated cross-section area:

2.5 mm² - 4,0 mm²

Rated ambient temperature:

-5°C up to + 40°C

Proof tracking index (PTI)

175 V

Insulation Class:

_

Degree of protection:

IP00

Variants covered by this Certificate are specified in the attached appendix.

A sample of the product has been tested and found in conformity with EN 60998-2-2:2004 and EN 60998-1:2004 as shown in the Test Report with ref. No. 05CA35047

The manufacturer complies with the Production Surveillance Requirements.

Products included in this Certificate are allowed to carry the marks ENEC 15. UI. International Demko A/S - as shown in annex 1.

This Certificate is only valid for products, which are identical to the certified product, and manufactured at the above mentioned production site(s).

UI. International Demko A/S has to be informed in writing about any changes, in accordance with the "UI. International Demko A/S Standard Terms and Conditions" for UI. International Demko A/S services. This document contains 2 page(s).

Herlev, 2005-10-17

Karina Christiansen Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514 DK-2730, Herley, Denmark Telephone: +45 44856565 Fax: +45 44856500



APPENDIX TO ENEC CERTIFICATE N° 140137-01

The Certificate covers the following:

Terminal Blocks 0,5 = 4,0 mm ² , Series 222, Non universal					
Item-No.	Nos. Of pole	s In all colo	urs Standard colour	Rated voltage V	
222-4	222-4X2	X	Light-grey	450	
222-4	222-4X3	X	Light-grey	450	
222-4	222-4X4	X	Light-grey	450	
222-4	222-4X5	X	Light-grey	450	

Production Sites:

WAGO Kontakttechnik GmbH Hansatrasse 27, D-32423 Minden Germany.

WAGO Contact GmbH Waldstrasse 1, D-99792 Berka/Wipper Germany.

WAGO Contact SA Zone Industrielle C, Case postale 168 CH-1564 Domdidier Switzerland.

Herley, 2005-10-17

Karina Christiansen Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514 DK-2730, Herlev, Denmark Telephone: +45 44856565 Fax: +45 44856500

